

Information sheet (Lot.10)

This information includes the results of calculation of the seasonal energy consumption and efficiency for air conditioner in regards to ErP pursuant to the Commission Regulation(EU) No.206/2012 and No.626/2011.

Information to identify the model(s) to which the information relates to:

AIR CONDITIONER
 TYPE : MULTI SPLIT
 WALL MOUNTED
 Indoor unit(s) : ASEH07KMCG x 4
 Outdoor unit : AOEK30KBT44
 BRAND : FUJITSU

N/A = Not Applicable

Function			
Cooling	Yes	Average	Yes
Heating	Yes	Warmer	No
		Colder	No

Design load				Seasonal efficiency			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Cooling	Pdesignc	8.0	kW	Cooling	SEER	8.50	-
Heating/Average	Pdesignh	6.5	kW	Heating/Average	SCOP/A	4.60	-
Heating/Warmer	Pdesignh	N/A	kW	Heating/Warmer	SCOP/W	N/A	-
Heating/Colder	Pdesignh	N/A	kW	Heating/Colder	SCOP/C	N/A	-

Cooling							
Declared capacity for cooling, at indoor temperature 27 (19) °C and outdoor temperature Tj				Declared energy efficiency ratio, at indoor temperature 27 (19) °C and outdoor temperature Tj			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = 35°C	Pdc	8.00	kW	Tj = 35°C	EER d	3.90	-
Tj = 30°C	Pdc	5.89	kW	Tj = 30°C	EER d	5.59	-
Tj = 25°C	Pdc	3.79	kW	Tj = 25°C	EER d	10.59	-
Tj = 20°C	Pdc	2.11	kW	Tj = 20°C	EER d	17.84	-

Heating/Average							
Declared capacity for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance/Average season, at indoor temperature 20 °C and outdoor temperature Tj			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = -7°C	Pdh	5.75	kW	Tj = -7°C	COPd	3.09	-
Tj = 2°C	Pdh	3.50	kW	Tj = 2°C	COPd	4.70	-
Tj = 7°C	Pdh	3.79	kW	Tj = 7°C	COPd	6.04	-
Tj = 12°C	Pdh	3.70	kW	Tj = 12°C	COPd	7.84	-
Tj = bivalent temperature	Pdh	5.75	kW	Tj = bivalent temperature	COPd	3.09	-
Tj = operating limit*	Pdh	5.20	kW	Tj = operating limit*	COPd	2.97	-

Heating/Warmer							
Declared capacity for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = 2°C	Pdh	N/A	kW	Tj = 2°C	COPd	N/A	-
Tj = 7°C	Pdh	N/A	kW	Tj = 7°C	COPd	N/A	-
Tj = 12°C	Pdh	N/A	kW	Tj = 12°C	COPd	N/A	-
Tj = bivalent temperature	Pdh	N/A	kW	Tj = bivalent temperature	COPd	N/A	-
Tj = operating limit*	Pdh	N/A	kW	Tj = operating limit*	COPd	N/A	-

Heating/Colder							
Declared capacity for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance/Colder season, at indoor temperature 20 °C and outdoor temperature Tj			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = -7°C	Pdh	N/A	kW	Tj = -7°C	COPd	N/A	-
Tj = 2°C	Pdh	N/A	kW	Tj = 2°C	COPd	N/A	-
Tj = 7°C	Pdh	N/A	kW	Tj = 7°C	COP d	N/A	-
Tj = 12°C	Pdh	N/A	kW	Tj = 12°C	COP d	N/A	-
Tj = bivalent temperature	Pdh	N/A	kW	Tj = bivalent temperature	COP d	N/A	-
Tj = operating limit*	Pdh	N/A	kW	Tj = operating limit*	COP d	N/A	-
Tj=-15°C	Pdh	N/A	kW	Tj = -15°C	COP d	N/A	-

Bivalent temperature				Operating limit temperature			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Heating/Average	Tbiv	-7	°C	Heating/Average	Tol	-15	°C
Heating/Warmer	Tbiv	N/A	°C	Heating/Warmer	Tol	N/A	°C
Heating/Colder	Tbiv	N/A	°C	Heating/Colder	Tol	N/A	°C

Cycling interval capacity				Cycling interval efficiency			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
For cooling	Pcycc	N/A	kW	For cooling	EERcyc	N/A	-
For heating	Pcych	N/A	kW	For heating	COPcyc	N/A	-
Degradation coefficient cooling	Cdc	0.25	-	Degradation coefficient heating	Cdh	0.25	-

Electric power input in power modes other than 'active mode'				Annual electricity consumption			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Off mode (Cooling/Heating)	P _{OFF}	4.0/4.0	W	Cooling	Q _{CE}	329	kWh/a
Standby mode (Cooling/Heating)	P _{SB}	4.0/4.0	W	Heating/Average	Q _{HE}	1978	kWh/a
Thermostat-off mode (Cooling/Heating)	P _{TO}	10.0/20.0	W	Heating/Warmer	Q _{HE}	N/A	kWh/a
Crankcase heater mode (Cooling/Heating)	P _{CK}	0.0/0.0	W	Heating/Colder	Q _{HE}	N/A	kWh/a

Capacity control		Other items		
Item	Y/N	Item	Symbol	Value Unit
Fixed	No	Sound power level (Indoor/Outdoor)	L _{WA}	54.0/63.0 dB(A)
Staged	No	Global warming potential	GWP	675 kgCO ₂ eq.
Variable	Yes	Rated air flow (Indoor/Outdoor)	-	650/2400 m ³ /h

Contact details for obtaining more information	GENERAL Inc. 3-3-17, Suenaga, Takatsu-ku, Kawasaki, 213-8502, Japan
--	--

* : Temperature at part load E condition(EN 14825)

V20121214

Information of indoor unit combination

Indoor unit combination (Wall-mounted type KM/KG/KE series only)

N/A = Not Applicable

Combination of indoor unit *1				Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
				Pdesignch	SEER	Q _{ch}		Pdesigngh	SCOP/A	Q _{ch}		Pdesigngh	SCOP/W	Q _{ch}		Pdesigngh	SCOP/C	Q _{ch}	
				kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
07	22	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	24	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	22	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	24	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	18	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	22	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	24	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	18	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	22	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	24	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	18	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	22	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	24	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22	22	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22	24	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
24	24	-	-	8.0	7.5	373	A++	6.5	4.1	2216	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	-	7.5	8.1	324	A++	6.0	4.4	1909	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	18	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	22	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	24	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	-	7.0	8.2	299	A++	6.0	4.4	1909	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	18	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	22	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	24	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	18	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	22	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	24	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	14	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	18	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	22	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	24	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	18	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	22	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	24	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	-	7.5	8.1	324	A++	6.0	4.4	1909	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	18	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	22	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	24	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

*1

07 = 7000Btu/h class = 2.0kW class

09 = 9000Btu/h class = 2.5kW class

12 = 12000Btu/h class = 3.5kW class

14 = 14000Btu/h class = 4.0kW class

18 = 18000Btu/h class = 5.0kW class

22 = 22000Btu/h class = 6.0kW class

24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (Wall-mounted type KM/KG/KE series only)

N/A = Not Applicable

Combination of indoor unit *1				Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
				Pdesigngh	SEER	Q _{ue}		Pdesigngh	SCOP/A	Q _{ue}		Pdesigngh	SCOP/W	Q _{ue}		Pdesigngh	SCOP/C	Q _{ue}	
				kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
09	12	12	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	18	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	22	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	24	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	14	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	18	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	22	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	24	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	14	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	18	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	22	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	24	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	14	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	18	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	22	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	24	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	14	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	18	-	8.0	8.0	350	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	12	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	14	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	18	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	14	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	18	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	12	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	14	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	18	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	14	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	18	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	12	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	14	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	18	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	12	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	14	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	18	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	14	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	18	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	12	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	14	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	18	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	14	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	18	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	12	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

*1

07 = 7000Btu/h class = 2.0kW class

09 = 9000Btu/h class = 2.5kW class

12 = 12000Btu/h class = 3.5kW class

14 = 14000Btu/h class = 4.0kW class

18 = 18000Btu/h class = 5.0kW class

22 = 22000Btu/h class = 6.0kW class

24 = 24000Btu/h class = 7.0kW class

N/A = Not Applicable

*1

07 =	7000Btu/h	class = 2.0kW	class
09 =	9000Btu/h	class = 2.5kW	class
12 =	12000Btu/h	class = 3.5kW	class
14 =	14000Btu/h	class = 4.0kW	class
18 =	18000Btu/h	class = 5.0kW	class
22 =	22000Btu/h	class = 6.0kW	class
24 =	24000Btu/h	class = 7.0kW	class

N/A = Not Applicable

*1

07 =	7000Btu/h	class = 2.0kW	class
09 =	9000Btu/h	class = 2.5kW	class
12 =	12000Btu/h	class = 3.5kW	class
14 =	14000Btu/h	class = 4.0kW	class
18 =	18000Btu/h	class = 5.0kW	class
22 =	22000Btu/h	class = 6.0kW	class
24 =	24000Btu/h	class = 7.0kW	class

Indoor unit combination (Wall-mounted type KM/KG/KE series including KJ series only)

N/A = Not Applicable

Combination of indoor unit *1				Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
				Pdesignc	SEER	Q _{net}		Pdesignh	SCOP/A	Q _{net}		Pdesignh	SCOP/W	Q _{net}		Pdesignh	SCOP/C	Q _{net}	
				kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
07	09	09	14	8.0	8.4	333	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	18	8.0	8.4	333	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	12	8.0	8.4	333	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	14	8.0	8.4	333	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	18	8.0	8.4	333	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	14	8.0	8.4	333	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	18	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	12	8.0	8.4	333	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	14	8.0	8.4	333	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	18	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	14	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	8.0	8.4	333	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	8.0	8.4	333	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	14	8.0	8.4	333	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	18	8.0	8.4	333	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	12	8.0	8.4	333	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	14	8.0	8.4	333	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	18	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	14	8.0	8.4	333	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	12	8.0	8.4	333	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	14	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	14	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	12	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

*1

07 = 7000Btu/h class = 2.0kW class

09 = 9000Btu/h class = 2.5kW class

12 = 12000Btu/h class = 3.5kW class

14 = 14000Btu/h class = 4.0kW class

18 = 18000Btu/h class = 5.0kW class

22 = 22000Btu/h class = 6.0kW class

24 = 24000Btu/h class = 7.0kW class

Indoor unit combinations (excluding combinations consisting only of wall-mounted units of the KM, KG, and KE series, including KJ series)

N/A = Not Applicable

Combination of indoor unit *1				Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	Design load kW	Seasonal efficiency SEER	Annual electricity consumption Q _g kWh/a	Energy efficiency class	Design load kW	Seasonal efficiency SCOP/A	Annual electricity consumption Q _g kWh/a	Energy efficiency class	Design load kW	Seasonal efficiency SCOP/W	Annual electricity consumption Q _g kWh/a	Energy efficiency class	Design load kW	Seasonal efficiency SCOP/C	Annual electricity consumption Q _g kWh/a	Energy efficiency class
05	22	-	-	7.5	6.0	438	A+	6.0	4.0	2100	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	24	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	22	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	24	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	22	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	24	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	18	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	22	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	24	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	18	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	22	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	24	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	18	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	22	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	24	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22	22	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22	24	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
24	24	-	-	8.0	5.9	475	A+	6.5	3.9	2333	A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	18	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	22	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	24	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	18	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	22	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	24	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	14	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	18	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	22	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	24	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	12	12	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	12	14	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	12	18	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	12	22	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	12	24	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	14	14	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	14	18	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	14	22	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	14	24	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	18	18	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	18	22	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	18	24	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	-	7.5	6.4	410	A++	6.0	4.1	2049	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	18	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	22	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	24	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	-	7.0	6.5	377	A++	6.0	4.1	2049	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	18	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	22	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	24	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	18	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	22	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	24	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	14	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	18	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	22	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	24	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	18	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	22	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	24	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	-	7.5	6.4	410	A++	6.0	4.1	2049	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	18	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	22	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	24	-	8.0	6.3	444	A++	6.5	4.0	2275	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

*1

05 = 5000Btu/h class = 1.5kW class

07 = 7000Btu/h class = 2.0kW class

09 = 9000Btu/h class = 2.5kW class

12 = 12000Btu/h class = 3.5kW class

14 = 14000Btu/h class = 4.0kW class

18 = 18000Btu/h class = 5.0kW class

22 = 22000Btu/h class = 6.0kW class

24 = 24000Btu/h class = 7.0kW class

N/A = Not Applicable

*1

05 =	5000Btu/h	class =	1.5kW	class
07 =	7000Btu/h	class =	2.0kW	class
09 =	9000Btu/h	class =	2.5kW	class
12 =	12000Btu/h	class =	3.5kW	class
14 =	14000Btu/h	class =	4.0kW	class
18 =	18000Btu/h	class =	5.0kW	class
22 =	22000Btu/h	class =	6.0kW	class
24 =	24000Btu/h	class =	7.0kW	class

Indoor unit combinations (excluding combinations consisting only of wall-mounted units of the KM, KG, and KE series, including KJ series)

N/A = Not Applicable

Combination of indoor unit *1				Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
				Pdesignhc	SEER	Q _g		Pdesignh	SCOP/A	Q _g		Pdesignh	SCOP/W	Q _g		Pdesignh	SCOP/C	Q _g	
				kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
07	12	12	12	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	14	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	18	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	14	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	14	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	18	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	12	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	14	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	18	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	14	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	12	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	14	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	14	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	12	8.0	6.7	418	A++	6.5	4.3	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

*1

05 = 5000Btu/h class = 1.5kW class

07 = 7000Btu/h class = 2.0kW class

09 = 9000Btu/h class = 2.5kW class

12 = 12000Btu/h class = 3.5kW class

14 = 14000Btu/h class = 4.0kW class

18 = 18000Btu/h class = 5.0kW class

22 = 22000Btu/h class = 6.0kW class

24 = 24000Btu/h class = 7.0kW class

Information of unit specification

Model Type	Model No.	Capacity Class	Dimension [H x W x D]	Sound power level(Cooling)	Sound power level(Heating)
		kW	mm	dB(A)	dB(A)
OUTDOOR	AOEG30KBT44	-	884 x 820 x 315	63	66
WALL MOUNTED	ASEH05KJCAL ASEH05KJCALB	1.5	270 x 798 x 240	50	50
	ASEH07KJCAL ASEH07KJCALB	2.0		51	51
	ASEH09KJCAL ASEH09KJCALB	2.5		55	56
	ASEH12KJCAL ASEH12KJCALB	3.5		56	56
	ASEH14KJCAL ASEH14KJCALB	4.0		59	59
	ASYH05KNCA	1.5	270 x 784 x 222	50	50
	ASYH07KNCA	2.0		51	51
	ASYH09KNCA	2.5		56	56
	ASYH12KNCA	3.5		57	57
	ASYG07KMCF ASEH07KMCG ASEH07KMCG-B	2.0	270 x 834 x 222	54	56
	ASYG09KMCF ASEH09KMCG ASEH09KMCG-B	2.5		55	57
	ASYG12KMCF ASEH12KMCG ASEH12KMCG-B	3.5		55	58
	ASYG14KMCF ASEH14KMCG ASEH14KMCG-B	4.0		57	59
	ASYG07KGTG ASEH07KGTG	2.0	270 x 834 x 215	54	56
	ASYG09KGTG ASEH09KGTG	2.5		55	57
	ASYG12KGTG ASEH12KGTG	3.5		56	58
	ASYG14KGTG ASEH14KGTG	4.0		57	59
	ASYG18KMTB ASYG18KMTG ASEH18KMTGL	5.0	280 x 980 x 240	60	61
	ASYG22KMTB ASYG22KMTG ASEH22KMTGL	6.0		62	62
	ASYG24KMTB ASYG24KMTG ASEH24KMTGL	7.0		65	65
	ASYG07KETF ASEG07KETF ASYG07KETF-B ASEG07KETF-B	2.0	295 x 950 x 230	54	56
	ASYG09KETF ASEG09KETF ASYG09KETF-B ASEG09KETF-B	2.5		55	57
	ASYG12KETF ASEG12KETF ASYG12KETF-B ASEG12KETF-B	3.5		55	58
	ASYG14KETF ASEG14KETF ASYG14KETF-B ASEG14KETF-B	4.0		57	59
CASSETTE	AUXG07KVL4	2.0	245 x 570 x 570 (Panel: 49 x 620 x 620)	46	47
	AUXG09KVL4	2.5		46	47
	AUXG12KVL4	3.5		49	49
	AUXG14KVL4	4.0		50	55
	AUXG18KVL4	5.0		50	55
	AUXG22KVL4	6.0		56	57
DUCT	ARXG07KSLAP	2.0	198 x 700 x 450	52	53
	ARXG09KSLAP	2.5		54	56
	ARXG12KSLAP	3.5		55	57
	ARXG14KSLAP	4.0		60	62
	ARXG18KSLAP	5.0	198 x 900 x 450	58	59
	ARXG07KLLAP	2.0	198 x 700 x 620	57	57
	ARXG09KLLAP	2.5		57	57
	ARXG12KLLAP	3.5		58	58
	ARXG14KLLAP	4.0		60	60
	ARXG18KLLAP	5.0	198 x 900 x 620	58	58
	ARXG22KMLB	6.0	270 x 1135 x 700	60	62
	ARXH12KMTAP	3.5	240 x 700 x 700	58	58
	ARXH14KMTAP	4.0		59	59
	ARXH18KMTAP	5.0		60	60
	ARXH22KMTAP	6.0	240 x 1000 x 700	58	58
FLOOR	AGYG09KVCA AGEG09KVCA AGEH09KVCCCL	2.5	600 x 740 x 200	52	52
	AGYG12KVCA AGEG12KVCA AGEH12KVCCCL	3.5		55	55
	AGYG14KVCA AGEG14KVCA AGEH14KVCCCL	4.0		56	56
CEILING	ABYG18KRTA ABEG18KRTA	5.0	235 x 1080 x 705	53	53
	ABYG22KRTA ABEG22KRTA	6.0		57	57