

Information sheet (Lot.10)

This information includes the results of calculation of the seasonal energy consumption and efficiency for air conditioner in regards to ErP pursuant to the Commission Regulation(EU) No.206/2012 and No.626/2011.

Information to identify the model(s) to which the information relates to:

AIR CONDITIONER
 TYPE : MULTI SPLIT
 WALL MOUNTED
 Indoor unit(s) : ASEH07KMCG x 5
 Outdoor unit : AOE36KBTA5
 BRAND : FUJITSU

N/A = Not Applicable

Function			
Cooling	Yes	Average	Yes
Heating	Yes	Warmer	No
		Colder	No

Design load				Seasonal efficiency			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Cooling	Pdesignc	9.5	kW	Cooling	SEER	8.50	-
Heating/Average	Pdesignh	7.0	kW	Heating/Average	SCOP/A	4.60	-
Heating/Warmer	Pdesignh	N/A	kW	Heating/Warmer	SCOP/W	N/A	-
Heating/Colder	Pdesignh	N/A	kW	Heating/Colder	SCOP/C	N/A	-

Cooling							
Declared capacity for cooling, at indoor temperature 27 (19) °C and outdoor temperature Tj				Declared energy efficiency ratio, at indoor temperature 27 (19) °C and outdoor temperature Tj			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = 35°C	Pdc	9.50	kW	Tj = 35°C	EER d	3.80	-
Tj = 30°C	Pdc	7.00	kW	Tj = 30°C	EER d	5.84	-
Tj = 25°C	Pdc	4.50	kW	Tj = 25°C	EER d	10.31	-
Tj = 20°C	Pdc	2.08	kW	Tj = 20°C	EER d	17.11	-

Heating/Average							
Declared capacity for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance/Average season, at indoor temperature 20 °C and outdoor temperature Tj			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = -7°C	Pdh	6.19	kW	Tj = -7°C	COPd	3.01	-
Tj = 2°C	Pdh	3.77	kW	Tj = 2°C	COPd	4.72	-
Tj = 7°C	Pdh	4.06	kW	Tj = 7°C	COPd	6.11	-
Tj = 12°C	Pdh	3.89	kW	Tj = 12°C	COPd	7.71	-
Tj = bivalent temperature	Pdh	6.19	kW	Tj = bivalent temperature	COPd	3.01	-
Tj = operating limit*	Pdh	5.80	kW	Tj = operating limit*	COPd	2.86	-

Heating/Warmer							
Declared capacity for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = 2°C	Pdh	N/A	kW	Tj = 2°C	COPd	N/A	-
Tj = 7°C	Pdh	N/A	kW	Tj = 7°C	COPd	N/A	-
Tj = 12°C	Pdh	N/A	kW	Tj = 12°C	COPd	N/A	-
Tj = bivalent temperature	Pdh	N/A	kW	Tj = bivalent temperature	COPd	N/A	-
Tj = operating limit*	Pdh	N/A	kW	Tj = operating limit*	COPd	N/A	-

Heating/Colder							
Declared capacity for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance/Colder season, at indoor temperature 20 °C and outdoor temperature Tj			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = -7°C	Pdh	N/A	kW	Tj = -7°C	COPd	N/A	-
Tj = 2°C	Pdh	N/A	kW	Tj = 2°C	COPd	N/A	-
Tj = 7°C	Pdh	N/A	kW	Tj = 7°C	COP d	N/A	-
Tj = 12°C	Pdh	N/A	kW	Tj = 12°C	COP d	N/A	-
Tj = bivalent temperature	Pdh	N/A	kW	Tj = bivalent temperature	COP d	N/A	-
Tj = operating limit*	Pdh	N/A	kW	Tj = operating limit*	COP d	N/A	-
Tj=-15°C	Pdh	N/A	kW	Tj = -15°C	COP d	N/A	-

Bivalent temperature				Operating limit temperature			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Heating/Average	Tbiv	-7	°C	Heating/Average	Tol	-15	°C
Heating/Warmer	Tbiv	N/A	°C	Heating/Warmer	Tol	N/A	°C
Heating/Colder	Tbiv	N/A	°C	Heating/Colder	Tol	N/A	°C

Cycling interval capacity				Cycling interval efficiency			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
For cooling	Pcycc	N/A	kW	For cooling	EERcyc	N/A	-
For heating	Pcyh	N/A	kW	For heating	COPcyc	N/A	-
Degradation coefficient cooling	Cdc	0.25	-	Degradation coefficient heating	Cdh	0.25	-

Electric power input in power modes other than 'active mode'				Annual electricity consumption			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Off mode (Cooling/Heating)	P _{OFF}	5.0/5.0	W	Cooling	Q _{CE}	391	kWh/a
Standby mode (Cooling/Heating)	P _{SB}	5.0/5.0	W	Heating/Average	Q _{HE}	2130	kWh/a
Thermostat-off mode (Cooling/Heating)	P _{TO}	11.0/23.0	W	Heating/Warmer	Q _{HE}	N/A	kWh/a
Crankcase heater mode (Cooling/Heating)	P _{CK}	0.0/0.0	W	Heating/Colder	Q _{HE}	N/A	kWh/a

Capacity control		Other items		
Item	Y/N	Item	Symbol	Value Unit
Fixed	No	Sound power level (Indoor/Outdoor)	L _{WA}	54.0/65.0 dB(A)
Staged	No	Global warming potential	GWP	675 kgCO ₂ eq.
Variable	Yes	Rated air flow (Indoor/Outdoor)	-	650/2450 m ³ /h

Contact details for obtaining more information	GENERAL Inc. 3-3-17, Suenaga, Takatsu-ku, Kawasaki, 213-8502, Japan
--	--

* : Temperature at part load E condition(EN 14825)

V20121214

Information of indoor unit combination

Indoor unit combination (Wall-mounted type KM/KG/KE series only)

N/A = Not Applicable

Combination of indoor unit *1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
					Pdesignc	SEER	QCE		Pdesignh	SCOP/A	QHE		Pdesignh	SCOPW	QHE		Pdesignh	SCOP/C	QHE	
					kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
07	24	-	-	-	9.0	7.9	399	A++	7.0	4.3	2279	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	22	-	-	-	8.5	7.9	377	A++	6.8	4.3	2214	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	24	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	22	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	24	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	22	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	24	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	18	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	22	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	24	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22	22	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22	24	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
24	24	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	-	-	8.0	8.2	341	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	18	-	-	9.0	8.1	389	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	-	-	8.0	8.2	341	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	-	-	8.5	8.1	367	A++	6.8	4.4	2164	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	-	-	9.0	8.1	389	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	-	-	7.5	8.2	320	A++	6.0	4.5	1867	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	-	-	8.5	8.1	367	A++	6.8	4.4	2164	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	-	-	9.0	8.1	389	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

*1

07 = 7000Btu/h class = 2.0kW class

09 = 9000Btu/h class = 2.5kW class

12 = 12000Btu/h class = 3.5kW class

14 = 14000Btu/h class = 4.0kW class

18 = 18000Btu/h class = 5.0kW class

22 = 22000Btu/h class = 6.0kW class

24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (Wall-mounted type KM/KG/KE series only)

N/A = Not Applicable

Combination of indoor unit *1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
					P _{designc}	SEER	Q _{CE}		P _{designh}	SCOP/A	Q _{HE}		P _{designh}	SCOPW	Q _{HE}		P _{designh}	SCOP/C	Q _{HE}	
					kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
09	12	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	18	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	18	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	18	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	18	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	18	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	18	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	18	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	18	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	18	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	18	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	-	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	-	8.5	8.4	354	A++	6.8	4.5	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	-	9.0	8.4	375	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

*1

07 = 7000Btu/h class = 2.0kW class

09 = 9000Btu/h class = 2.5kW class

12 = 12000Btu/h class = 3.5kW class

14 = 14000Btu/h class = 4.0kW class

18 = 18000Btu/h class = 5.0kW class

22 = 22000Btu/h class = 6.0kW class

24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (Wall-mounted type KM/KG/KE series only)

N/A = Not Applicable

Combination of indoor unit *1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
					P _{designc}	SEER	Q _{CE}		P _{designh}	SCOP/A	Q _{HE}		P _{designh}	SCOPW	Q _{HE}		P _{designh}	SCOP/C	Q _{HE}	
					kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
07	07	12	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	18	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	18	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	14	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

*1

07 = 7000Btu/h class = 2.0kW class

09 = 9000Btu/h class = 2.5kW class

12 = 12000Btu/h class = 3.5kW class

14 = 14000Btu/h class = 4.0kW class

18 = 18000Btu/h class = 5.0kW class

22 = 22000Btu/h class = 6.0kW class

24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (Wall-mounted type KM/KG/KE series only)

N/A = Not Applicable

Combination of Indoor unit *1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
					P _{designh}	SEER	Q _{CE}		P _{designh}	SCOP/A	Q _{HE}		P _{designh}	SCOPW	Q _{HE}		P _{designh}	SCOP/C	Q _{HE}	
					kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
09	09	12	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	18	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	07	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	09	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	22	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	24	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	09	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	22	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	24	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	12	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	12	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	14	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	14	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	09	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	14	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	14	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	09	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

*1

07 = 7000Btu/h class = 2.0kW class

09 = 9000Btu/h class = 2.5kW class

12 = 12000Btu/h class = 3.5kW class

14 = 14000Btu/h class = 4.0kW class

18 = 18000Btu/h class = 5.0kW class

22 = 22000Btu/h class = 6.0kW class

24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (Wall-mounted type KM/KG/KE series including KJ series only)

N/A = Not Applicable

Combination of indoor unit *1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
					Pdesign/kW	SEER	Qep kWh/a	-	Pdesign/kW	SCOP/A	Qhe kWh/a	-	Pdesign/kW	SCOPW	Qhe kWh/a	-	Pdesign/kW	SCOP/C	Qhe kWh/a	-
05	22	-	-	-	7.5	8.2	320	A++	6.0	4.3	1953	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	24	-	-	-	8.5	7.9	376	A++	6.8	4.2	2265	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	24	-	-	-	9.0	7.9	399	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	22	-	-	-	8.5	7.9	376	A++	6.8	4.3	2212	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	24	-	-	-	9.5	7.8	426	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	22	-	-	-	9.5	7.8	426	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	24	-	-	-	9.5	7.8	426	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	22	-	-	-	9.5	7.8	426	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	24	-	-	-	9.5	7.8	426	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	18	-	-	-	9.5	7.8	426	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	22	-	-	-	9.5	7.8	426	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	24	-	-	-	9.5	7.8	426	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22	22	-	-	-	9.5	7.8	426	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22	24	-	-	-	9.5	7.8	426	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
24	24	-	-	-	9.5	7.8	426	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	18	-	-	8.0	8.2	341	A++	6.5	4.4	2067	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	22	-	-	9.0	8.1	389	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	24	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	18	-	-	8.5	8.1	367	A++	6.8	4.3	2212	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	22	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	24	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	14	-	-	8.0	8.2	341	A++	6.5	4.4	2067	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	18	-	-	9.0	8.1	389	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	22	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	24	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	12	12	-	-	8.5	8.1	367	A++	6.8	4.3	2212	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	12	14	-	-	9.0	8.1	389	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	12	18	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	12	22	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	12	24	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	14	14	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	14	18	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	14	22	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	14	24	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	18	18	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	18	22	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	18	24	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	22	22	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	22	24	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	24	24	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	-	-	8.0	8.2	341	A++	6.5	4.4	2067	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	18	-	-	9.0	8.1	389	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	22	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	24	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	-	-	8.0	8.2	341	A++	6.5	4.4	2067	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	-	-	8.5	8.1	367	A++	6.8	4.3	2212	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	18	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	22	-	-	9.5	8.0	410	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	24	-	-	9.5	8.0	410	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	-	-	9.0	8.1	389	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	18	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	22	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	24	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	14	-	-	9.5	8.0	410	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	18	-	-	9.5	8.0	410	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	22	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	24	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	18	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	22	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	24	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	-	-	7.5	8.2	320	A++	6.0	4.4	1908	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	-	-	8.5	8.1	367	A++	6.8	4.3	2212	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	-	-	9.0	8.1	389	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	18	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	22	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	24	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	18	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	22	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	24	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	14	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	18	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	22	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	24	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	18	18	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	18	22	-	-	9.5	8.0	410	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	18	24	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

*1

05 = 5000Btu/h class = 1.5kW class

07 = 7000Btu/h class = 2.0kW class

09 = 9000

N/A = Not Applicable

Combination of Indoor unit *1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
					Pdesigngh kW	SEER	Q _E kWh/a	-	Pdesigngh kW	SCOP/A	Q _E kWh/a	-	Pdesigngh kW	SCOP/W	Q _E kWh/a	-	Pdesigngh kW	SCOP/C	Q _E kWh/a	-
12	12	14	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	18	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	22	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	24	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	14	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	18	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	22	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	24	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	18	18	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	18	22	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	18	24	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	14	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	18	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	22	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	24	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	18	18	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	18	18	-	-	9.5	8.0	416	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	12	-	8.0	8.4	333	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	14	-	8.5	8.4	354	A++	6.8	4.4	2162	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	22	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	24	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	07	12	-	8.5	8.1	367	A++	6.8	4.4	2162	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	07	14	-	9.0	8.4	375	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	07	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	07	22	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	07	24	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	09	09	-	8.0	8.4	333	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	09	12	-	9.0	8.4	375	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	09	14	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	09	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	09	22	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	09	24	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	12	12	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	12	14	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	12	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	12	22	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	12	24	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	14	14	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	14	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	14	22	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	14	24	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	18	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	18	22	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	18	24	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	07	09	-	8.0	8.4	333	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	07	12	-	9.0	8.4	375	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	07	14	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	07	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	07	22	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	07	24	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	09	09	-	8.5	8.4	354	A++	6.8	4.4	2162	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	09	12	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	09	14	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	09	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	09	22	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	09	24	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	12	12	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	12	14	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	12	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	12	22	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	12	24	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	14	14	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	14	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	14	22	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	14	24	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	18	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	18	22	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	18	24	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	09	09	-	9.0	8.4	375	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	09	12	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	09	14	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	09	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	09	22	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	09	24	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	12	12	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	12	14	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	12	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	12	22	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	12	24	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

8 / 19

N/A = Not Applicable

Combination of Indoor unit *1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
					Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
room1	room2	room3	room4	room5																
05	09	14	14	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
05	09	14	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
05	09	14	22	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
05	09	14	24	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
05	09	18	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
05	09	18	22	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
05	12	12	12	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
05	12	12	14	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
05	12	12	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
05	12	12	22	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
05	12	12	24	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
05	12	14	14	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
05	12	14	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
05	12	14	22	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
05	12	18	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
05	14	14	14	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
05	14	14	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	07	07	07	-	8.0	8.4	333	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	07	07	09	-	8.5	8.4	354	A++	6.8	4.4	2162	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	07	07	12	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	07	07	14	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	07	07	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	07	07	22	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	07	07	24	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	07	09	09	-	9.0	8.4	375	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	07	09	12	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	07	09	14	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	07	09	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	07	09	22	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	07	09	24	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	07	12	12	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	07	12	14	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	07	12	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	07	12	22	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	07	12	24	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	07	14	14	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	07	14	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	07	14	22	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	07	14	24	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	07	18	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	09	09	09	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	09	09	12	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	09	09	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	09	09	22	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	09	09	24	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	09	12	12	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	09	12	14	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	09	12	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	09	12	22	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	09	12	24	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	09	14	14	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	09	14	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	09	14	22	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	09	14	24	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	09	18	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	12	12	12	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	12	12	14	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	12	12	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	12	14	14	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
07	12	14	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
09	09	09	09	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
09	09	09	12	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
09	09	09	14	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
09	09	09	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
09	09	09	22	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
09	09	09	24	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
09	09	12	12	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
09	09	12	14	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
09	09	12	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
09	09	12	22	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
09	09	12	24	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
09	09	14	14	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
09	09	14	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
09	09	18	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
09	12	12	12	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
09	12	12	14	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
09	12	12	18	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
09	12	12	24	-	9.5	8.3	401	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

*1

05 =	5000Btu/h	class = 1.5kW	class
07 =	7000Btu/h	class = 2.0kW	class
09 =	9000Btu/h	class = 2.5kW	class
12 =	12000Btu/h	class = 3.5kW	class
14 =	14000Btu/h	class = 4.0kW	class
18 =	18000Btu/h	class = 5.0kW	class
22 =	22000Btu/h	class = 6.0kW	class
24 =	24000Btu/h	class = 7.0kW	class

N/A = Not Applicable

*1

05 =	5000Btu/h class = 1.5kW class
07 =	7000Btu/h class = 2.0kW class
09 =	9000Btu/h class = 2.5kW class
12 =	12000Btu/h class = 3.5kW class
14 =	14000Btu/h class = 4.0kW class
18 =	18000Btu/h class = 5.0kW class
22 =	22000Btu/h class = 6.0kW class
24 =	24000Btu/h class = 7.0kW class

N/A = Not Applicable

*1

05 =	5000Btu/h	class = 1.5kW	class
07 =	7000Btu/h	class = 2.0kW	class
09 =	9000Btu/h	class = 2.5kW	class
12 =	12000Btu/h	class = 3.5kW	class
14 =	14000Btu/h	class = 4.0kW	class
18 =	18000Btu/h	class = 5.0kW	class
22 =	22000Btu/h	class = 6.0kW	class
24 =	24000Btu/h	class = 7.0kW	class

Indoor unit combination (Wall-mounted type KM/KG/KE series including KJ series only)

N/A = Not Applicable

Combination of Indoor unit *1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
					Pdesign/c	SEER	Q _g /t	-	Pdesign/h	SCOP/A	Q _h /t	-	Pdesign/h	SCOPW	Q _h /t	-	Pdesign/h	SCOP/C	Q _h /t	-
					kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
07	09	09	12	12	9.5	8.4	396	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	12	14	9.5	8.4	396	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	14	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	12	12	9.5	8.4	396	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	12	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	09	9.5	8.4	395	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	12	9.5	8.4	396	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	14	9.5	8.4	396	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	12	9.5	8.4	396	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

*1

05 = 5000Btu/h class = 1.5kW class

07 = 7000Btu/h class = 2.0kW class

09 = 9000Btu/h class = 2.5kW class

12 = 12000Btu/h class = 3.5kW class

14 = 14000Btu/h class = 4.0kW class

18 = 18000Btu/h class = 5.0kW class

22 = 22000Btu/h class = 6.0kW class

24 = 24000Btu/h class = 7.0kW class

Indoor unit combinations (excluding combinations consisting only of wall-mounted units of the KM, KG, and KE series, including KJ series)

N/A = Not Applicable

Combination of indoor unit *1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
					Pdesigngh	SEER	Q _g	-	Pdesigngh	SCOP/A	Q _g	-	Pdesigngh	SCOP/W	Q _g	-	Pdesigngh	SCOP/C	Q _g	-
					kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
05	22	-	-	-	7.5	6.1	430	A++	6.0	4.1	2049	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	24	-	-	-	8.5	6.0	496	A+	6.8	4.0	2380	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	24	-	-	-	9.0	6.0	525	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	22	-	-	-	8.5	6.0	496	A+	6.8	4.0	2380	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	24	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	22	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	24	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	22	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	24	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	18	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	22	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	24	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22	22	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22	24	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
24	24	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	18	-	-	8.0	6.3	444	A++	6.5	4.2	2167	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	22	-	-	9.0	6.2	508	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	18	-	-	8.5	6.2	480	A++	6.8	4.1	2322	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	14	-	-	8.0	6.3	444	A++	6.5	4.2	2167	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	18	-	-	9.0	6.2	508	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	12	12	-	-	8.5	6.2	480	A++	6.8	4.1	2322	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	12	14	-	-	9.0	6.2	508	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	12	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	12	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	12	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	14	14	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	14	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	14	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	14	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	18	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	18	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	18	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	22	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	22	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	24	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	-	-	8.0	6.3	444	A++	6.5	4.2	2167	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	18	-	-	9.0	6.2	508	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	-	-	8.0	6.3	444	A++	6.5	4.2	2167	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	-	-	8.5	6.2	480	A++	6.8	4.1	2322	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	-	-	9.0	6.2	508	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	14	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	-	-	7.5	6.3	417	A++	6.0	4.2	2000	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	-	-	8.5	6.2	480	A++	6.8	4.1	2322	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	-	-	9.0	6.2	508	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

*1

05 = 5000Btu/h class = 1.5kW class

07 = 7000Btu/h class = 2.0kW class

09 = 9000Btu/h class = 2.5kW class

12 = 12000Btu/h class = 3.5kW class

14 = 14000Btu/h class = 4.0kW class

18 = 18000Btu/h class = 5.0kW class

22 = 22000Btu/h class = 6.0kW class

24 = 24000Btu/h class = 7.0kW class

N/A = Not Applicable

*1

05 =	5000Btu/h class = 1.5kW class
07 =	7000Btu/h class = 2.0kW class
09 =	9000Btu/h class = 2.5kW class
12 =	12000Btu/h class = 3.5kW class
14 =	14000Btu/h class = 4.0kW class
18 =	18000Btu/h class = 5.0kW class
22 =	22000Btu/h class = 6.0kW class
24 =	24000Btu/h class = 7.0kW class

N/A = Not Applicable

*1

05 =	5000Btu/h class = 1.5kW class
07 =	7000Btu/h class = 2.0kW class
09 =	9000Btu/h class = 2.5kW class
12 =	12000Btu/h class = 3.5kW class
14 =	14000Btu/h class = 4.0kW class
18 =	18000Btu/h class = 5.0kW class
22 =	22000Btu/h class = 6.0kW class
24 =	24000Btu/h class = 7.0kW class

Indoor unit combinations (excluding combinations consisting only of wall-mounted units of the KM, KG, and KE series, including KJ series)

N/A = Not Applicable

Combination of indoor unit *1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
					Pdesignch	SEER	Q _{ac}		Pdesigngh	SCOP/A	Q _{he}		Pdesigngh	SCOPW	Q _{he}		Pdesigngh	SCOP/C	Q _{he}	
					kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
09	09	12	24	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	18	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	12	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	14	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	12	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	14	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	14	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	05	07	8.0	6.7	418	A++	6.5	4.4	2068	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	05	09	8.5	6.6	451	A++	6.8	4.3	2214	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	05	12	9.5	6.5	512	A++	7.0	4.3	2279	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	05	14	9.5	6.5	512	A++	7.0	4.3	2279	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	05	18	9.5	6.5	512	A++	7.0	4.3	2279	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	05	22*2	9.5	6.5	512	A++	7.0	4.3	2279	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	05	24	9.5	6.5	512	A++	7.0	4.3	2279	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	07	07	8.5	6.6	451	A++	6.8	4.3	2214	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	07	09	9.0	6.6	477	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	07	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	07	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	07	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	07	22*2	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	07	24	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	09	09	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	09	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	09	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	09	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	09	22*2	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	09	24	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	12	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	12	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	12	22	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	12	24	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	14	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	14	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	14	22*2	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	14	24	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	05	18	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	07	07	07	9.0	6.6	477	A++	7.0	4.2	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	07	07	09	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	07	07	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	07	07	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	07	07	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	07	07	22*2	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	07	07	24	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	07	09	09	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	07	09	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	07	09	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	07	09	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	07	09	22*2	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	07	09	24	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	09	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	09	12	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	09	12	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	09	12	22*2	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	09	14	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	09	14	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	09	14	24	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	12	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

*1

05 = 5000Btu/h class = 1.5kW class

07 = 7000Btu/h class = 2.0kW class

09 = 9000Btu/h class = 2.5kW class

12 = 12000Btu/h class = 3.5kW class

14 = 14000Btu/h class = 4.0kW class

18 = 18000Btu/h class = 5.0kW class

22 = 22000Btu/h class = 6.0kW class

24 = 24000Btu/h class = 7.0kW class

*2

As for the 22 model, WALL MOUNTED type indoor unit is only connectable.

Indoor unit combinations (excluding combinations consisting only of wall-mounted units of the KM, KG, and KE series, including KJ series)

N/A = Not Applicable

Combination of indoor unit *1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load Pdesignh kW	Seasonal efficiency SEER	Annual electricity consumption Q _g kWh/a	Energy efficiency class	Design load Pdesignh kW	Seasonal efficiency SCOP/A	Annual electricity consumption Q _g kWh/a	Energy efficiency class	Design load Pdesignh kW	Seasonal efficiency SCOPW	Annual electricity consumption Q _g kWh/a	Energy efficiency class	Design load Pdesignh kW	Seasonal efficiency SCOP/C	Annual electricity consumption Q _g kWh/a	Energy efficiency class
05	05	12	12	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	12	12	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	12	14	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	12	14	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	14	14	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	07	07	07	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	07	07	09	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	07	07	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	07	07	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	07	07	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	07	07	22*2	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	07	07	24	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	07	09	09	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	07	09	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	07	09	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	07	09	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	07	09	22*2	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	07	09	24	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	07	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	07	12	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	07	12	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	07	12	22*2	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	07	14	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	07	14	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	09	09	09	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	09	09	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	09	09	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	09	09	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	09	09	22*2	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	09	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	09	12	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	09	12	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	09	14	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	12	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	12	12	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	12	14	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	12	12	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	07	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	09	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	22*2	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	24	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	09	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	22*2	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	24	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	12	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	12	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	14	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	09	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	22*2	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	14	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

*1

05 = 5000Btu/h class = 1.5kW class

07 = 7000Btu/h class = 2.0kW class

09 = 9000Btu/h class = 2.5kW class

12 = 12000Btu/h class = 3.5kW class

14 = 14000Btu/h class = 4.0kW class

18 = 18000Btu/h class = 5.0kW class

22 = 22000Btu/h class = 6.0kW class

24 = 24000Btu/h class = 7.0kW class

*2

As for the 22 model, WALL MOUNTED type indoor unit is only connectable.

Indoor unit combinations (excluding combinations consisting only of wall-mounted units of the KM, KG, and KE series, including KJ series)

N/A = Not Applicable

Combination of indoor unit *1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
					Pdesignc	SEER	Q _{LT}	-	Pdesignh	SCOP/A	Q _{HT}	-	Pdesignh	SCOPW	Q _{HT}	-	Pdesignh	SCOP/C	Q _{HT}	-
					kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
07	07	12	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	12	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	14	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	09	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	12	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	14	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	12	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	09	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

*1

05 = 5000Btu/h class = 1.5kW class

07 = 7000Btu/h class = 2.0kW class

09 = 9000Btu/h class = 2.5kW class

12 = 12000Btu/h class = 3.5kW class

14 = 14000Btu/h class = 4.0kW class

18 = 18000Btu/h class = 5.0kW class

22 = 22000Btu/h class = 6.0kW class

24 = 24000Btu/h class = 7.0kW class

Model Type	Model No.	Capacity Class	Dimension [H x W xD]	Sound power level(Cooling)	Sound power level(Heating)
		kW	mm	dB(A)	dB(A)
OUTDOOR	AOEG36KBTAS	-	884 x 820 x 315	65	68
WALL MOUNTED	ASEH05KJCAL	1.5	270 x 798 x 240	50	50
	ASEH05KJCALB	2.0		51	51
	ASEH07KJCAL			55	56
	ASEH07KJCALB	2.5		56	56
	ASEH09KJCAL			59	59
	ASEH09KJCALB	3.5		50	50
	ASEH12KJCAL			51	51
	ASEH12KJCALB	4.0		56	56
	ASEH14KJCAL		57	57	
	ASEH14KJCALB	270 x 784 x 222	54	56	
	ASEH05KNCA		55	57	
	ASEH07KNCA		57	59	
	ASEH09KNCA		54	56	
	ASEH12KNCA	55	57		
	ASYG07KMCF	2.0	270 x 834 x 222	55	58
	ASEH07KMCG	2.5		57	59
	ASEH07KMCG-B			54	56
	ASYG09KMCF	3.5		55	57
	ASEH09KMCG			56	58
	ASEH09KMCG-B	4.0		57	59
	ASYG12KMCF			54	56
	ASEH12KMCG	55		57	
	ASEH12KMCG-B	270 x 834 x 215	56	58	
	ASYG14KMCF		57	59	
	ASEH14KMCG		54	56	
	ASEH14KMCG-B		55	57	
	ASYG07KGTG	2.0	270 x 834 x 215	56	58
	ASEH07KGTG	2.5		57	59
	ASYG09KGTG			54	56
	ASEH09KGTG	55		57	
	ASYG12KGTG	3.5	280 x 980 x 240	60	61
	ASEH12KGTG	4.0		62	62
	ASYG14KGTG			65	65
	ASEH14KGTG	5.0		62	62
	ASEG18KMTE	6.0	295 x 950 x 230	54	56
	ASEG18KMTE	7.0		55	57
ASEH18KMTGL	56			58	
ASEG22KMTE	7.0	57		59	
ASEG22KMTE	2.0	245 x 570 x 570 (Panel: 49 x 620 x 620)	46	47	
ASEH22KMTGL			47	47	
ASYG24KMTE			49	49	
ASEG24KMTE			50	55	
ASEH24KMTGL	50		55		
ASYG07KETF	2.5		56	57	
ASEG07KETF			55	56	
ASYG07KETF-B	3.5		57	59	
ASEG07KETF-B		54	56		
ASYG09KETF	4.0	55	57		
ASEG09KETF		56	58		
ASYG09KETF-B	198 x 700 x 450	57	59		
ASEG09KETF-B		58	60		
ASYG12KETF		59	60		
ASEG12KETF		60	60		
ASYG12KETF-B	198 x 700 x 620	57	57		
ASEG12KETF-B		57	57		
ASYG14KETF		58	58		
ASEG14KETF		58	58		
ASYG14KETF-B	198 x 900 x 620	57	57		
ASEG14KETF-B		57	57		
ASYG14KETFB		58	58		
ASEG14KETFB		58	58		
AUXG07KVLA	2.0	245 x 570 x 570 (Panel: 49 x 620 x 620)	46	47	
AUXG09KVLA	2.5		47	47	
AUXG12KVLA	3.5		49	49	
AUXG14KVLA	4.0		50	55	
AUXG18KVLA	5.0		50	55	
AUXG22KVLA	6.0		56	57	
DUCT	ARXG07KSLAP	2.0	198 x 700 x 450	52	53
	ARXG09KSLAP	2.5		54	56
	ARXG12KSLAP	3.5		55	57
	ARXG14KSLAP	4.0		60	62
	ARXG18KSLAP	5.0	198 x 900 x 450	58	59
	ARXG07KLLAP	2.0	198 x 700 x 620	57	57
	ARXG09KLLAP	2.5		57	57
	ARXG12KLLAP	3.5		58	58
	ARXG14KLLAP	4.0		60	60
	ARXG18KLLAP	5.0	198 x 900 x 620	58	58
	ARXG22KMLB	6.0	270 x 1135 x 700	60	62
	ARXH12KMTAP	3.5	240 x 700 x 700	58	58
	ARXH14KMTAP	4.0		59	59
	ARXH18KMTAP	5.0		60	60
	ARXH22KMTAP	6.0		240 x 1000 x 700	58
	FLOOR	AGYG09KVCA	2.5	600 x 740 x 200	52
AGEG09KVCA		3.5	55		55
AGEH09KVCCL			56		56
AGYG12KVCA		4.0	55		55
AGEG12KVCA			56		56
AGEH12KVCCL		56	56		
CEILING	ABYG18KRTA	5.0	235 x 1080 x 705	53	53
	ABEG18KRTA	6.0		57	57
	ABYG22KRTA			53	53
	ABEG22KRTA	57		57	